

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2022/SZ/322

Dated: 29/03/2022

FIRE SAFETY CERTIFICATE

Certified that the **D.C. Convent School**, RZ-115 Shiv Nagar, Raghbir Enclave, Najafgarh, New Delhi-110043, Comprised of ground plus two upper floors & one room on terrace using for Store, owned/occupied by D.C. Convent School have complied with the fire prevention and fire safety requirements in accordance with the Rules 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 09/03/2022 in the presence of Mr. Kuldeep Dagar (Manager) and found that the school building (Ground plus two upper floors only) is fit for occupancy class B 'Educational Building' for with effect from 29/03/2022 for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 29/03/2022 at New Delhi by


 (Kuldeep Dagar)
 Director


Delhi Fire Service

Copy to:-

1. The Manager, D.C. Convent School, RZ-115 Shiv Nagar, Raghbir Enclave, Najafgarh, New Delhi-110043.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.


 Principal
D.C. CONVENT SCHOOL
 RZ-115, Shiv Nagar, Near Dichaon
 Chowk, Najafgarh, N.D.


 Manager
D.C. CONVENT SCHOOL
 RZ-115, Shiv Nagar, Near Dichaon